

**OIML Member State**  
The Netherlands

Number R60/2000-NL1-11.15  
Project number 11200241  
Page 1 of 2

Issuing authority	NMi Certin B.V. Person responsible: C. Oosterman
Applicant	Anyload Transducer Co. Ltd 6994 Greenwood Street, Unit 102 Burnaby, BC Canada V5A 1X8
Manufacturer	Anyload Youngzon Transducer (Hangzhou) Co.Ltd. No.160, South No.11 Street, Hangzhou Economic & Technological Development Zone, Zhejiang, Hangzhou, China, 310018
Identification of the certified type	A compression <b>Load Cell</b> Type : 102DH
Characteristics	See next page

This Certificate attests the conformity of the above identified Type (represented by the sample(s) identified in the OIML Test Report) with the requirements of the following Recommendation of the International Organization of Legal Metrology (OIML):

**OIML R60** - Edition 2000 (E) for accuracy class C

This Certificate relates only to the metrological and technical characteristics of the type of measuring instrument covered by the relevant OIML International Recommendation above-identified. This Certificate does not bestow any form of legal international approval.

*Important note:* Apart from the mention of the Certificate's reference number and the name of the OIML Member State in which the Certificate was issued, partial quotation of the Certificate and of the associated OIML Test Report(s) is not permitted, although either may be reproduced in full.

Issuing Authority **NMi Certin B.V., OIML Issuing Authority NL1**  
12 July 2011



C. Oosterman  
Head Certification Board

NMi Certin B.V.  
Hugo de Grootplein 1  
3314 EG Dordrecht  
the Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The notification of NMi Certin B.V. as Issuing Authority can be verified at [www.oiml.org](http://www.oiml.org)

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see [www.nmi.nl](http://www.nmi.nl)).





# OIML Certificate of Conformity

**OIML Member State**  
The Netherlands

Number R60/2000-NL1-11.15  
Project number 11200241  
Page 2 of 2

The conformity was established by the results of tests and examinations provided in the associated OIML Test Report(s):

- No. NM-11200241-01 dated 12 July 2011 that includes 65 pages.

## Characteristics of the Load Cell:

- Fraction  $P_i$  : 0,7
- Maximum capacity ( $E_{max}$ ) : 9000 kg up to and including 45000 kg
- Humidity Class : CH
- Temperature range : -10 °C / +40 °C
- Accuracy Class : C
- Maximum number of load cell intervals (n) : 4000
- Ratio of minimum LC Verification interval : 15000
- $Y = E_{max} / V_{min}$
- Ratio of minimum dead load output return : 4000
- $Z = E_{max} / (2 * DR)$