



NATIONAL TYPE EVALUATION PROGRAM

Certificate of Conformance
for Weighing and Measuring Devices

For:

Load Cell
Tension
Model: 110xx Series
 n_{max} : 6000, Class III, Single Cell and Multiple Cell
Capacity: 5000 to 50 000 kg
Accuracy Class: III

Submitted By:

Anyload LLC
Bldg. 8, Unit 68, 1275 Bloomfield Ave.
Fairfield, NJ 07004
Tel: (855) 269-5623
Fax: (866) 612-9088
Contact: Gary Gui
Email: gary.gui@load-cell.com
Web site: www.anyload.net

Standard Features and Options

- Model 110xx, where the x in the model designation may be BH, BS, FH, FS, NH, NS, KH, KS, WH, WS, YH, YS, QH, QS, PH, PS, HH, ZH, ZS
- The specific load cell capacities, v_{min} values, and minimum dead loads covered by this Certificate are listed in the table below.
- Nominal output: 2.0 and 3.0 mV/V
- Steel material
- 4 wire design
- Minimum Dead Load: 0 kg

Models	Capacity *load cell tested	V_{min} Class III Single cell, n= 6000
110xx	5000 kg	0.35 kg
	7500 kg	0.53 kg
	10 000 kg*	0.7 kg
	15000 kg*	1.05 kg
	20 000 kg	1.4 kg
	30 000 kg	2.1 kg
	50 000 kg	3.5 kg
*Load cell tested		

Temperature Range: -10 °C to 40 °C (14 °F to 104 °F)

This device was evaluated under the National Type Evaluation Program and was found to comply with the applicable technical requirements of "NIST Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices." Evaluation results and device characteristics necessary for inspection and use in commerce are on the following pages.

Stephen Benjamin
Chairman, NCWM, Inc.

Kurt Floren
Chairman, National Type Evaluation Program Committee
Issued: August 2, 2012

1135 M Street, Suite 110 / Lincoln, Nebraska 68508

The National Conference on Weights and Measures (NCWM) does not approve, recommend or endorse any proprietary product or material, either as a single item or as a class or group. Results shall not be used in advertising or sales promotion to indicate explicit or implicit endorsement of the product or material by the NCWM.



Anyload LLC

Load Cell / 110xx Series

Application: The load cells may be used in Class III scales for single cell and multiple cell applications consistent with the model designations, number of scale divisions, and parameters specified in this certificate. Load cells of a given accuracy class may be used in applications with lower accuracy class requirements provided the number of scale divisions, the v_{\min} value, and temperature range are suitable for the application. The manufacturer may market the load cell with fewer divisions (n_{\max}) and with greater v_{\min} values than those listed on the certificate. However, the load cells must be marked with the appropriate n_{\max} and v_{\min} for which the load cell may be used.

Identification: A pressure sensitive identification label located on the cell, states manufacturer name, model, serial number, rated capacity, class and v_{\min} . Other pertinent information will be specified on the Calibration Certificate accompanying the cell.

Test Conditions: Two Model 110BH, 10 000 kg and 15 000 kg capacity load cells were tested by the NMI Certain B.V. at The Netherlands facility. Testing was conducted in accordance with the OIML DoMC Mutual Acceptance Arrangement, signed by the NCWM as a utilizing participant for load cell testing. Testing was conducted using deadweights as the reference standard. The load cells were tested over a temperature range of -10°C to 40°C with tests run on each cell at each temperature. The temperature effect on zero was measured and a time dependence (creep) test was performed. The barometric pressure test to determine sensitivity of the load cell design to changes in barometric pressure was conducted. The data were analyzed for single load cell applications. OIML R60 selection criteria were used to determine cells tested.

Evaluated By: E. van der Grinten, R. Scholten (NMI)

Type Evaluation Criteria Used: NIST, Handbook 44: Specifications, Tolerances and Other Technical Requirements for Weighing and Measuring Devices, 2012. NCWM, Publication 14: Weighing Devices, 2012.

Conclusion: The results of the evaluation and information provided by the manufacturer indicate the device complies with applicable requirements.

Information Reviewed By: J. Truex (NCWM)

Examples of Device:

